



Safety Values Award

Muhammed Anzal

AC Thermal Plant

His quick thinking and prompt attention prevented a fire from spreading. At the beginning of his shift he heard a noise from the control room office and checked the cameras to find smoke coming from the thermal oil pump. He found fire and smoke in the area of the coupling between the pump and motor. He immediately went back to the office to confirm which pump was running and switch the pump off then extinguished the fire. He then opened some doors to let the smoke out of the area and notified his supervisor.