Dalhousie University, Department of Facilities Management Confined Space Inventory Form

| Building: Building B (J051), Sexton Campus | Room Number: | Date: <u>June 25, 2013</u> | |
|---|-------------------------------------|----------------------------|--|
| Confined Space No: <u>J051 – HW – 01</u> | Confined Space Class: | | |
| Description of Space: Steam and condensate line chamber. | | | |
| The floor access panel / hatch is located across the hall from door B-099. | | | |
| Construction Material: Concrete with steel cover. | | | |
| Method of Entry: Access ladder required. | No. of Acc | cess / Egress Points: 1 | |
| Dimensions of Access / Egress Opening: | | | |
| Length: 00.0 inches Width: 00.0 inches E | Depth: 55.0 inches approx. Di | iameter: 23.5 inches | |
| Type of Work Normally Conducted in Space: Maintenance and repair to pumps, valves and condensate traps. | | | |
| Frequency of Work Performance: <u>As required.</u> | | | |
| Reference Atmospheric Testing: CO ppm | H ₂ S ppm O ₂ | % LEL% | |
| Other: | | | |
| | | | |

| Potential Hazards List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety. | | |
|---|---|--|
| | | |
| Oxygen Hazard: | | |
| | | |
| | | |
| | | |
| | | |
| Electrical Hazards: | | |
| Shock from power cords for pumps | Disconnect and isolate power source. Keep cords out of water. | |
| | | |
| Mechanical Hazards: | | |
| | | |
| | | |
| | | |
| | | |

| Physical Hazards: | |
|-----------------------|--|
| Steam and condensate. | |
| | |
| Chemicals Hazards: | |
| | |
| | |
| | |
| Biological: | |
| | |
| | |
| Additional Comments: | |
| | |
| | |
| | |

Photographs





Photo Numbers: <u>2013 – 06 – 25 (0917)</u>

<u>2013 – 06 – 25 (0918)</u>

| ist Emergency Procedures: |
|---------------------------|
| |
| |
| |
| |
| |
| Assessment Conducted By: |
| Signature: |
| Phone number: |
| Date: |