

Dalhousie University, Department of Facilities Management

Confined Space Inventory Form

Building: <u>Gerrard Hall J910</u>	Room Number: <u>Sub Basement</u>	Date: <u>June 25, 2013</u>
Confined Space No: <u>J910 – SB – 02</u>	Confined Space Class: _____	
Description of Space: <u>Elevator sump pump pit #4.</u> <u>Located just to the right of the elevators.</u>		
Construction Material: <u>Concrete with steel grating hatches.</u>		
Method of Entry: <u>Ladder required for access.</u>		No. of Access / Egress Points: <u>1</u>
Dimensions of Access / Egress Opening:		
<u>Length: 48.0 inches Width: 48.0 inches Depth: 126.0 inches</u>		
Type of Work Normally Conducted in Space: <u>Servicing of sump pumps and floats.</u>		
Frequency of Work Performance: <u>As required.</u>		
Reference Atmospheric Testing: CO _____ ppm H ₂ S _____ ppm O ₂ _____ % LEL _____ %		
Other: _____		

Potential Hazards

List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety.

Potential Hazards	Recommended Control Measures
Oxygen Hazard:	
Electrical Hazards: Shock from power cords for pumps	Disconnect and isolate power source. Keep cords out of water.
Mechanical Hazards:	

Physical Hazards: Water	Pump water out of pit.
Chemicals Hazards:	
Biological:	
Additional Comments:	

Photographs



Photo Numbers: 2013 - 06 - 25 (1249)

2013 - 06 - 25 (1250)

List Emergency Procedures:

Assessment Conducted By: _____

Signature: _____

Phone number: _____

Date: _____