Dalhousie University, Department of Facilities Management Confined Space Inventory Form

Building: Ken Rowe Bldg.	Room Number: <u>G09</u>	Date: October 19, 2011		
Confined Space No: E260 – G09 – 01	Confined Space Class:			
Description of Space:				
Sewage / Sanitary pit.				
Construction Material: Concrete with a steel cover.				
Method of Entry: <u>Climbing down ladder.</u>	No. of Access / Egress Points: 1			
Dimensions of Access / Egress Opening:				
Length: 39.0 inches Width: 39.0 inches	Depth: Diameter	:		
Type of Work Normally Conducted in Space: Servicing of pumps and float switches.				
Frequency of Work Performance: <u>As required.</u>				
Reference Atmospheric Testing: CO ppm	H ₂ Sppm O ₂	% LEL %		
Other:				

Potential Hazards				
List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety.				
Potential Hazards	Recommended Control Measures			
Oxygen Hazard:				
Electrical Hazards:				
Electrical power to pumps.	Isolate energy sources and lock out.			
Mechanical Hazards:				
Confirm existence of mechanical hazards.				

Physical Hazards:		
Chemicals Hazards:		
Flammables:		
Additional Comments:		
May be biological hazards.		

Photographs





Photo Numbers: 2011 - 10 - 19 - 09 2011 - 10 - 19 - 10

List Emergency Procedures:		
Assessment Conducted By:		
Signature:	_	
Phone number:	-	
Date:		