

Dalhousie University, Department of Facilities Management

Confined Space Inventory Form

Location: <u>Life Sciences, Oceanography C202</u>	Room Number: <u>Hall Way (HW)</u>	Date: <u>August 22, 2013</u>
Confined Space No: <u>C202 – SC – 01</u>	Confined Space Class: _____	
<p>Description of Space: This is a steam chamber.</p> <p>Construction Material: <u>Concrete and stone with a wood access door.</u></p> <p><u>Partially under ramp leading to door at SW corner of Oceanography Bldg.</u></p> <p>Method of Entry: <u>Ladder required.</u> No. of Access / Egress Points: <u>1</u></p>		
<p>Dimensions of Access / Egress Opening:</p> <p>The approximate internal dimensions are width 4.0 ft. by length 10.0 ft. by depth 7.0 ft.</p>		
<p>Type of Work Normally Conducted in Space: <u>Maintenance, servicing, inspection.</u></p> <p>Frequency of Work Performance: <u>As required</u></p>		
<p>Reference Atmospheric Testing: CO _____ ppm H₂S _____ ppm O₂ _____ % LEL _____ %</p> <p>Other: _____</p>		

Potential Hazards

List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety.

Potential Hazards

Recommended Control Measures

Oxygen Hazard:

Electrical Hazards:

Mechanical Hazards:

<p>Physical Hazards:</p> <p>Burns from steam</p> <p>Excessive Heat</p>	<p>Lock out and tag</p> <p>Ventilate</p>
<p>Chemicals Hazards:</p>	
<p>Biological:</p>	
<p>Additional Comments:</p> <p>Do not enter unless energy source has been isolated and steam line has been locked out and tagged.</p>	

Photographs



Photo Number: 2013 - 08 - 22 (1240)



2013 - 08 - 22 (1241)

List Emergency Procedures:

Assessment Conducted By: _____ Signature: _____

Phone number: _____

Date: _____