

Dalhousie University, Department of Facilities Management

Confined Space Inventory Form

Location: <u>Sherriff Hall C220</u>	Room Number: <u>Hall Way (HW)</u>	Date: <u>August 22, 2013</u>
Confined Space No: <u>C220 – HW – 01</u>	Confined Space Class: _____	
<p>Description of Space: This space is a utility tunnel for water, steam, drainage lines, condensate line, propane line and electrical. There is a sump pump in the back left corner.</p> <p>Construction Material: <u>Concrete and stone with a wood access door.</u></p> <p>Method of Entry: <u>Ladder required.</u> No. of Access / Egress Points: <u>1</u></p>		
Dimensions of Access / Egress Opening:		
<p>Type of Work Normally Conducted in Space: <u>Maintenance, servicing, inspection.</u></p> <p>Frequency of Work Performance: <u>As required</u></p>		
<p>Reference Atmospheric Testing: CO _____ ppm H₂S _____ ppm O₂ _____ % LEL _____ %</p> <p>Other: _____</p>		

Potential Hazards

List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety.

Potential Hazards	Recommended Control Measures
Oxygen Hazard:	
Electrical Hazards: Electrical lines	
Mechanical Hazards:	

<p>Physical Hazards:</p> <p>Uncontrolled energy sources such as water drainage liquids. Burns from steam. Flammable substance</p>	<p>Lock out and tag</p> <p>Lock out and tag and blank</p> <p>Lock out and tag</p>
<p>Chemicals Hazards:</p>	
<p>Biological:</p>	
<p>Additional Comments:</p>	

Photographs



Photo Number: 2013 - 08 - 22 (1232)



2013 - 08 - 22 (1233)

List Emergency Procedures:

Assessment Conducted By: _____ Signature: _____

Phone number: _____

Date: _____