

**Dalhousie University, Department of Facilities Management**

**Confined Space Inventory Form**

Location: <u>Intersection of Breton and Morris St.</u>	Room Number: <u>N/A</u>	Date: <u>June 25, 2013</u>
Confined Space No: <u>Steam Chamber # 05</u>	Confined Space Class: _____	
<p>Description of Space: <u>Chamber provides access to a condensate line (not in use) and a pressurized steam line.</u></p> <p><u>See form for Steam Chamber #10 for further information.</u></p> <p>Construction Material: <u>Concrete with manhole covers.</u></p> <p>Method of Entry: <u>Ladder required for access.</u>                      No. of Access / Egress Points: <u>1</u></p>		
<p>Dimensions of Access / Egress Opening:</p> <p><u>Diameter: 28.0 inches          Depth:</u></p>		
<p>Type of Work Normally Conducted in Space: <u>Servicing of lines and valves and sump pumps if they are present.</u></p> <p>Frequency of Work Performance: <u>As required.</u></p>		
<p>Reference Atmospheric Testing: CO _____ ppm H<sub>2</sub>S _____ ppm O<sub>2</sub> _____ % LEL _____ %</p> <p>Other: _____</p>		

### Potential Hazards

List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety.

Potential Hazards	Recommended Control Measures
Oxygen Hazard:	
Electrical Hazards:  Electrical where there are sump pumps.	
Mechanical Hazards:	

<p>Physical Hazards:</p> <p>High pressure steam. Vehicle Traffic</p>	<p>Implement appropriate traffic control measures</p>
<p>Chemicals Hazards:</p>	
<p>Biological:</p>	
<p>Additional Comments:</p>	

## Photographs



Photo Number: 2013 - 06 - 25 (1333)

List Emergency Procedures:

Assessment Conducted By: \_\_\_\_\_

Signature: \_\_\_\_\_

Phone number: \_\_\_\_\_

Date: \_\_\_\_\_