

Dalhousie University, Department of Facilities Management

Confined Space Inventory Form

Location: <u>Intersection of Morris and Birmingham</u>	Room Number: <u>N/A</u>	Date: <u>June 25, 2013</u>
Confined Space No: <u>Steam Chamber # 07</u>	Confined Space Class: _____	
Description of Space: <u>Chamber provides access to a condensate line (not in use) and a pressurized steam line.</u> <u>See form for Steam Chamber #10 for further information.</u>		
Construction Material: <u>Concrete with manhole covers.</u>		
Method of Entry: <u>Ladder required for access.</u>		No. of Access / Egress Points: <u>1</u>
Dimensions of Access / Egress Opening: <u>Diameter: 28.0 inches Depth:</u>		
Type of Work Normally Conducted in Space: <u>Servicing of lines and valves and sump pumps if they are present.</u>		
Frequency of Work Performance: <u>As required.</u>		
Reference Atmospheric Testing: CO _____ ppm H ₂ S _____ ppm O ₂ _____ % LEL _____ % Other: _____		

Potential Hazards

List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety.

Potential Hazards	Recommended Control Measures
Oxygen Hazard:	
Electrical Hazards: Electrical where there are sump pumps.	
Mechanical Hazards:	

<p>Physical Hazards:</p> <p>High pressure steam. Vehicle Traffic</p>	<p>Implement appropriate traffic control measures</p>
<p>Chemicals Hazards:</p>	
<p>Biological:</p>	
<p>Additional Comments:</p>	

Photographs



Photo Numbers: 2013 – 06 – 25 (1325)

List Emergency Procedures:

Assessment Conducted By: _____

Signature: _____

Phone number: _____

Date: _____