

Dalhousie University, Department of Facilities Management

Confined Space Inventory Form

Building: <u>Tupper F200</u>	Room Number: <u>PH</u>	Date: <u>June 19, 2013</u>
Confined Space No: <u>F200 – PH – 02</u>	Confined Space Class: _____	
Description of Space: <u>Laboratory Hot Water Tank</u>		
Construction Material: <u>Unsure of internal surface.</u>		
Method of Entry: <u>Ladder required to access man way.</u>		No. of Access / Egress Points: <u>1</u>
Dimensions of Access / Egress Opening:		
Length: <u>00.0 inches</u>	Width: <u>00.0 inches</u>	Depth: <u>00.0 ft. approx.</u> Diameter: <u>00.0 inches</u>
Type of Work Normally Conducted in Space: <u>Maintenance of tank and / or resurfacing of inside.</u>		
Frequency of Work Performance: <u>As required.</u>		
Reference Atmospheric Testing: CO _____ ppm H ₂ S _____ ppm O ₂ _____ % LEL _____ %		
Other: _____		

Potential Hazards

List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety.

Potential Hazards	Recommended Control Measures
Oxygen Hazard: Possibility of poor air quality when tank is first opened.	Sample air quality and take appropriate control measures if necessary.
Electrical Hazards:	
Mechanical Hazards:	

<p>Physical Hazards:</p> <p>Water in bottom of pit.</p> <p>If concrete is used inside tank, asbestos may be an issue.</p>	<p>Ensure all water is removed from tank before doing any work.</p> <p>Check for asbestos. If present take all appropriate control measures.</p>
<p>Chemicals Hazards:</p>	
<p>Biological:</p>	
<p>Additional Comments:</p>	

Photographs



Photo Numbers: 2013 - 06 - 19 (1423)



2013 - 06 - 19 (1427)

List Emergency Procedures:

Assessment Conducted By: _____

Signature: _____

Phone number: _____

Date: _____