

Dalhousie University, Department of Facilities Management

Confined Space Inventory Form

Building: <u>University Club</u>	Room Number: <u>Comm. Room</u>	Date: <u>June 13, 2013</u>
Confined Space No: <u>C440 – CR – 01</u>	Confined Space Class: _____	
Description of Space: <p align="center"><u>Steam, Condensate and Electrical Service Tunnel</u></p> <p><u>Access through door at back left of billiards room. Go through locker room into Communications Room.</u></p>		
Construction Material:		
Method of Entry: <u>Crawl into tunnel.</u> No. of Access / Egress Points: <u>1</u>		
Dimensions of Access / Egress Opening:		
Length: <u>26.5 inches</u> Width: <u>25.5 inches</u> Depth: <u>00.0 ft. approx.</u> Diameter: <u>00.0 inches</u>		
Type of Work Normally Conducted in Space: <u>Repairs to or replacing of pipes and electrical lines.</u>		
Frequency of Work Performance: <u>As required.</u>		
Reference Atmospheric Testing: CO _____ ppm H ₂ S _____ ppm O ₂ _____ % LEL _____ %		
Other: _____		

Potential Hazards

List all hazards near the access / egress opening(s) or in the confined space that must be controlled to ensure employee safety.

Potential Hazards	Recommended Control Measures
Oxygen Hazard:	
Electrical Hazards: Electrical lines	Isolate all unnecessary electrical circuits and lock out. Keep equipment power cords out of water.
Mechanical Hazards:	

<p>Physical Hazards:</p> <p>Protruding pipes, High pressure steam Water Condensate</p>	<p>Isolate all energy sources and lock out.</p>
<p>Chemicals Hazards:</p>	
<p>Biological:</p>	
<p>Additional Comments:</p> <p>Tunnel goes through to Chemistry Bldg.</p>	

Photographs



Photo Numbers: 2013 - 06 - 13 (1257)



2013 - 06 - 13 (1257)

List Emergency Procedures:

Assessment Conducted By: _____

Date: _____

Signature: _____

Phone number: _____