



**DALHOUSIE  
UNIVERSITY**

Department of  
Facilities Management  
Occupational Health and Safety

**Confined Space Program**

**Atmospheric Testing Log**

Date: \_\_\_\_\_ Work Order No. \_\_\_\_\_ Test Performed By: \_\_\_\_\_

Building \_\_\_\_\_ Confined Space Inventory ID # \_\_\_\_\_

Testing Frequency: Continuous \_\_\_ 30 Minutes \_\_\_ 1 Hour \_\_\_ 2 Hours \_\_\_ 3 Hours \_\_\_ 4 Hours \_\_\_

**Note: If the confined space is vacant for more than 30 minutes the atmosphere must be tested before anyone re-enters the space.**

Time 24 Hour Clock	Initials	Oxygen 19.5% – 22.5%	% LEL < 10% for cold work < 0% for hot work 10% to 49% for cleaning	Carbon Monoxide 25 PPM for low limit 50 PPM for high limit	Hydrogen Sulphide 1.0 PPM low limit 5.0 PPM high limit	Other Toxics Or Comments

Version: 1 | Effective Date: March 2015 | Revision Date: \_\_\_\_\_